

TRANSFER CAPABILITY OF PUNJAB CONTROL AREA

Sr. No.	Duration	Time Period (in hrs.)	Total Transfer Capability (TTC) of Pb. (MW) (a)	Reliability Margin (MW) (b)	Available Transfer Capability (ATC) of Pb. (MW) (c) = (a) - (b)	Long Term Access (LTA)/Medium Term Open Access (MTOA) (MW) (d)	ATC for Short-Term Open Access (STOA) (MW) (e) = (c)-(d)
1	Sep11 - April12	00-24	5000	300	4700	2850	1850
2	May12- Aug12	00-24	5400	300	5100	3000	2100
3	Dec12- Feb13	Peak hours	5100	300	4800	2800	2000
		Off-Peak hours	4800	300	4500	2800	1700
4	May13- July13	00-24	5600	300	5300	3350	1950
5	May14- July14	00-24	5700	300	5400	3790	1610
6	May15- Aug15	00-24	6200	500	5700	4033	1667
7	May16- Aug16	00-24	6400	500	5900	4102	1798
8	May17- June17	00-24	6500	600	5900	4261	1639
9	July17- Sept17	00-24	6700	600	6100	4261	1839
10	June18 - Sep18	00-24	7000	600	6400	4680	1720